

Lower Mid Rawa Khola Hydroelectric Project

4.00 MW

Khotang, Nepal

**Developer:
Lower Mid Rawa Khola Hydropower
Project Pvt. Ltd., Kathmandu**





MODES OF PRESENTATION

1. Project Description
2. Hydrology
3. Power and Energy
4. Project Cost
5. Power Evacuation
6. Site Photographs



PROJECT DESCRIPTION

LOCATION MAP



Location:

**Sapteshwor and Rakha Bangdel VDC,
Khotang, District, Province No.-I**



PROJECT OVERVIEW

Location: *Sapteshwor and Rakha Bangdel VDC, Khotang, District,*
Province No.-I

Accessibility:

Kathmandu to Hurlung

245 km (black topped)

Hurlung to Project Area /

Powerhouse area

20 km (gravel road)

Design discharge (Q42.44%):

3.80 m³/s

Gross head:

140.12m

Net Head:

130.00m

SURVEY LICENSE

Survey License Received license on 2074/12/29

License No: 997

Capacity: 4.00 MW

Company Registration: 2076/03/02 (June 17, 2019)

Company Name: Lower Mid Rawakhola Hydropower Project Pvt. Ltd

Current Stage: Applied for PPA (On July 29, 2019)

This is fast Moving Project

Strength of the project


- * Access road available
- * Far from main settlement area and less social problem
- * Aiselukhark Gounpalika is decided to invest **10% in equity**
- * Aiselukharka Gaunplaika ward No 1, is ready to work jointly with the project
- * Free construction materials available : stone, sand, gravel and soil are in construction site
- * Strong management team
- * Fast moving project
- * Payback start from the next year of construction completion

Risk to the Project

Challenges:

- * Meeting timeline for the project
- * Timely Availability of fund
- * Possible Political unrest
- * Timely supply of electromechanical equipment

PROJECT LAYOUT




Weir/Intake (Weir Crest: 967.32 amsl)

PROJECT PROFILE


Desander (2bay, 40.00m x 5.00m x 6.40m)

Penstock Pipe (1.5m Ø, L = 4180.22 m)


Powerhouse 22.70mx 9.50mx 10.52m
Turbine axis Level :827.20 amsl






HEADWORKS PLAN / PROFILE



WEIR SECTION



POWERHOUSE PLAN PROFILE SECTION



SALIENT FEATURES OF THE PROJECT


Type	: Run-of-the- river
Design Discharge (Q56)	: 3.80 m ³ /sec
Gross head	: 140.12 m
Net head	: 130.00 m
Installed Capacity	: 4.00 MW
Length of Penstock Pipe	: 4180.22 m
Total Saleable Energy	: 24.08 GWh
Turbine	: Horizontal Axis Francis Turbine (2 units),
Overall Efficiency	: 86.42%
Turbine axis level	: 827.20 masl
Transmission Line	: About 7km Single circuit/S to Baghshila Substation– 33 kV
Access road	: About 10 Km from Sapteshwor to Powerhouse
Project Cost	: 833.543 mill. NRs (208.385 mill. NRs / MW)
IRR	: 15.47%
EIRR	: 22.97%
Payback period	: 11.96 years (discounted)

A decorative graphic at the top of the slide consisting of a solid blue rectangular area above a series of overlapping, wavy, light blue shapes that resemble water or a stylized landscape.

HYDROLOGY

CATCHMENT PHYSIOGRAPHY

Catchment Area of Rawa khola at Proposed Headworks and Powerhouse Site



✓ Rawa Khola is a perennial snow fed river originating from Makalu Barun National Park

Catchment area at Intake = **102.46** Km²

Catchment area at Powerhouse = **109.51** Km²

Elevation	Intake		Powerhouse	
	Area (Km ²)	%	Area (Km ²)	%
5000m-3000m	12.27	12.00%	12.27	11.20%
<3000m	90.19	88.00%	97.25	88.80%
Total	102.46	100.00%	109.51	100.00%

PRECIPITATION (BASIN RAINFALL) DETAIL

Raingauge station lying in the vicinity of the catchment

Index No.	Station name	Record		Annual precipitation (mm)	Monsoon Ppt
		Length	Period		
1204	Aiselukhark	35	1975-2009	2256	1815
1222	Diktel	36	1975-2010	1436	1097
1324	Bhojpur	30	1974 – 2003	1245	861
1325	Dingla	35	1975-2009	1923	1455



Details of Gauging Stations Considered for Regional Analysis

Name of River	Station No.	Location	Elevation (m)	Area (Km ²)	Record	
					Length (yrs)	Period
Sabhaya khola	602	Tumlingtar	305	409	42	1974 - 2015
Hinwa khola	602.5	Pipletar	300	154	33	1974 - 2006
Rosi khola	640	Panauti	1480	89	24	1964 - 1987
Khimti Khola	650	Rasnal	1120	343	41	1964 - 2013
Mai	728	Rajdwali	609	396	26	1983 - 2008

LONG TERM MEAN MONTHLY FLOW

Total Estimated Long term Mean Monthly and Yearly Flow (m³/s) by Different Methods at the Intake Site of Lower Mid Rawa Khola HEP

Months	Flow (cumecs)				
	Car Method with Gauging	CAR Method with Gauging Station	Regional Analysis	Hydest	Modified Hydest



CONTINUE.....

Long Term Mean monthly flow in terms of Nepali Calendar

Month	Discharge (m ³ /s)
Baisakh (Apr/May)	2.10
Jestha (May/Jun)	4.38
Jestha 1 to 15	3.31
Jestha 16 to 31	5.39
Ashadh (Jun/Jul)	8.50
Shrawan (Jul/Aug)	10.90
Bhadra (Aug/Sep)	10.41
Ashwin (Sep/Oct)	7.38
Kartik (Oct/Nov)	4.24
Mangsir (Nov/Dec)	2.57
Mangsir 1 to 15	2.85
Mangsir 16 to 29	2.28
Poush (Dec/Jan)	1.69
Magh (Jan/Feb)	1.21
Falgun (Feb/Mar)	0.98
Chaitra (Mar/May)	1.03
Average	4.62


*Rainfall runoff coefficient
calculation using Isohyetal
method at Lower Mid Rawa
Khola HEP Headworks*

Catchment Area (Km ²)	102.46
Average Annual Precipitation (mm)	1902
Average Annual Discharge (m ³ /s)	4.66
Annual Runoff Volume (mm)	1434.4
Runoff / Rainfall	0.75

FLOW DURATION CURVE

Estimated Available Flow (m^3/s) for Different Percentile of Time Exceedence of a Year at the Proposed Intake Site from CAR Method and Regression Analysis

Probability of Excedence (%)	CAR Method with Gauging Station 602.5	CAR Method with Gauging Station 602	Regression Analysis
5	13.42	20.17	8.58
10	10.50	15.93	7.23



EXTREME HYDROLOGY

Low Flows at the Proposed Headworks Site of Lower Mid Rawa Khola HEP, m³/s

Return Period, yrs	Duration			
	1 Day	7 Days	30 Days	Monthly
2	1.08	1.159	1.362	1.465
10	0.679	0.721	0.914	1.001
20	0.611	0.642	0.832	0.917

Estimated Flood Flow from Reference Station #602 and #602.5 at the Proposed Intake Site, m³/s

Return Period in yrs	Flood Flow (m ³ /s) at the Proposed Intake Site					
	With Reference to G Station #602			With Reference to G Station #602.5		
	GEV	3P-LN	LP III	GEV	3P-LN	LP III
2	124	118	132	29	29	29
5	193	198	197	38	39	39
10	257	279	244	44	44	44
20	339	383	294	49	50	49
50	484	558	364	55	56	55
100	632	725	420	59	61	59
200	825	931	482	63	65	63
500	1171	1264	569	67	71	67

CONTINUE.....

Estimated Flood Flow from Reference Station #602 and #602.5 at the Proposed Powerhouse Site, m³/s

Return Period in yrs		Flood Flow (m ³ /s) at the Proposed Powerhouse Site					
		With Reference to G Station #602			With Reference to G Station #602.5		
		CEV	35 IN	15 IN	CEV	35 IN	15 IN
Return Period in yrs	Headworks Site			Powerhouse Site			
	Hydest		Modified Hydest	Hydest		Modified Hydest	
	Daily	Instantaneous		Daily	Instantaneous		
	Estimated Flood Flow from Hydest and Modified Hydest Methods at Intake and Powerhouse site, m ³ /s						
2	60	99	110	64	106	117	
5	91	164	193	97	175	205	
10	113	214	258	120	227	274	
20	134	267	329	143	282	348	
50	164	341	432	175	361	456	
100	188	402	529	200	425	559	
200	212	467	611	226	493	645	
500	246	561	747	261	591	787	
1000	273	637	861	290	671	906	

POWER AND ENERGY GENERATION

ENERGY CALCULATION PARAMETER


Weir crest level	=	967.320 m
Turbine axis level	=	827.20 m
Gross head	=	140.12 m
Design discharge	=	3.80 m ³ /s (Q42.44%)
Downstream release	=	0.095 m ³ /s
Outage	=	5%
Turbine efficiency	=	90%
Generator efficiency	=	97%
Transformer efficiency	=	99%
Overall efficiency	=	86.42%

AVAILABLE DISCHARGE


Month	Days	River flow (m ³ /s)	Available flow (m ³ /s)	Plant discharge (m ³ /s)
Baisakh	31	2.10	2.00	2.00
Jestha	31	4.38	4.28	3.80
Ashadh	31	8.50	8.40	3.80
Shrawan	32	10.90	10.80	3.80
Bhadra	31	10.41	10.31	3.80
Ashwin	31	7.38	7.28	3.80
Kartik	30	4.24	4.14	3.80
Mangsir	29	2.57	2.47	2.47
Poush	30	1.69	1.59	1.59
Magh	29	1.21	1.11	1.11
Falgun	30	0.98	0.88	0.88
Chaitra	30	1.03	0.93	0.93

ENERGY TABLE

Design discharge:	3.80 m ³ /s
Downstream release	0.098 m ³ /s
Gross Head	140.12 m
Turbine Efficiency	90.00%
Generator Efficiency	97.00%
Transformer Efficiency	99.00%
Outage:	5%



Generation	Contract Energy
with outage	with outage
(KWh)	(KWh)
1,639,776.00	1,639,776
2,827,200.00	2,827,200
2,827,200.00	2,827,200






PROJECT COST

PROJECT COST

Description	Amount
General Item	36,400,000.00
Civil Works	189,211,570.87
Electro Mechanical Works	225,411,570.87


Project Cost



A blue header bar at the top of the page, featuring a white wavy line that separates it from the main content area. Below the wavy line, there are several overlapping, semi-transparent light blue shapes that create a layered, wave-like effect.

POWER EVACUATION PLAN


TRANSMISSION LINE



CONCLUSIONS

- ✓ Recording of gauge heights, regular measurement of discharges and sediment sampling at the gauging station should be continued at Rawa Khola for accurate Energy Calculations.
- ✓ Immediate action for land procurement, planning for construction of infrastructure facilities and preparation of site for the construction of the project should be done in time which will result easy to mobilization contractor soon .
- ✓ The power generated from the project shall be evacuated to the switchyard of the Baghshila S/S of NEA, Khotang with 33 kV switching arrangement for which about 7 KM transmission line needs to be constructed timely.
- ✓ The Project is environmentally, Technically and Financial feasible and worth to invest to develop.

PHOTOGRAPHS



GAUGE FIXING AND WATER MEASUREMENT

Intake Site



Reasons for Investment in Hydro

- * Guaranteed Buyer (PPA signed before Project starts)
- * Attractive Rate of Return on investments (25-30% or even 35%)
- * Availability of Bank finances
- * Cross-border electricity transmission lines and regional power trade agreements has opened up unlimited opportunities to produce and trade power in the region
- * Green Energy is preferred energy. It is the future
- * Tax Preferences for income from Hydro plans
- * Low staff and low operational and maintenance costs allowing companies to manage multiple projects at once
- * Long term Cash Flow could replace your retirement income

